

MEMORANDUM

(RJS/DWF/CJW)

MEMO BY Roger T. Pelote TO Ron L. Nelson DATE July 21, 1983  
FILE TITLE IPP Air Quality Permit Modification

I telephoned Dave Kopta, DOH staff engineer, today to determine the status of their review of our July 18 submittal. Dave informed me of the following:

- Brent Bradford plans to issue a Notice of Intent (NOI) on Monday or Tuesday (7-25 or 7-26),
- The NOI will state that a NO<sub>x</sub> emission limit in the range of 0.50 - 0.55 lb./10<sup>6</sup>Btu is recommended; The actual value will not be determined until after the public comment period.
- John Walton has not found any new sources of information on NO<sub>x</sub> control review.
- The NOI will have the existing SO<sub>2</sub> control conditions of 0.15 lb./10<sup>6</sup>Btu and 90% removal.
- The NOI may delete the provision allowing one exception per hour for the 20% opacity limit.

As you know, a NO<sub>x</sub> emission limit below 0.55 would have very serious adverse consequences to the Project. After reviewing the NOI next week, we will recommend a strategy and course of action on this issue.

Deletion of the one exception for opacity does not appear to be a change of significant impact at this time; however, we will prepare an impact analysis on this issue.

Dave called back to inform me that our fugitive dust analysis appears to be acceptable but he plans a review to assign new conditions at a later date.

cc : J.H. Anthony      Henry Nickel      J.J. Carnerale  
E.G. Gladbach      Andrea Bear      D.W. Fowler  
J.E. Helt      Jim Holtkamp      N.F. Bassin  
T.L. Conkin  
R.T. Pelote